

# PFAS in Cape Cod Private Wells

## SUPPLEMENTAL DATA

The table shows additional information about the individual PFAS chemicals measured.

Chemical	Percent of wells in which this chemical was detected	Maximum concentration detected (parts per trillion, ppt)
<b>PFAS included in Massachusetts drinking water standard ("PFAS6")</b>		
PFHxS	77%	8.7 ppt
PFOA	66%	9.9 ppt
PFOS	52%	4.7 ppt
PFNA	31%	0.6 ppt
PFHpA	25%	8.3 ppt
PFDA	9%	0.7 ppt
<b>Other PFAS (not included in Massachusetts drinking water standard)</b>		
PFHxA	68%	116 ppt
PFPeA	62%	135 ppt
PFBA	55%	27 ppt
PFPeS	52%	0.5 ppt
FOSA	48%	1.5 ppt
PFHpS	34%	0.5 ppt
FBSA	12%	1.4 ppt
PFBS	11%	37 ppt
6:2 FTS	6%	1.7 ppt
FHxSA	5%	0.34 ppt
MeFBSA	2%	1.4 ppt
PFUnDA	2%	0.11 ppt
PFDoDA	2%	0.09 ppt
PFNS	2%	0.08 ppt

For more information about STEEP's Community Engagement Core activities on Cape Cod, visit: [uri.edu/steep/steep-cores/community-engagement/](https://uri.edu/steep/steep-cores/community-engagement/)

