

Safety and Lighting Walk Report
URI Student Senate Campus Affairs
Fall 2013

Chairwoman Amanda Rode
amanda_rode@my.uri.edu
Wednesday, October 17, 2013

Blue Light Concerns

Immediate Action Required:

- #21 and #9, both the blue light and the call button do not work. These lights are areas that are more dangerous to students because there are at the bottom of campus and not several surrounding buildings.
- The light by Weldin, both the blue light and call button do not work
- The blue light between Quinn and Pastore does not exist, but is indicated on the campus map.

Light Does Not Work:

- #3, Fine Arts Center
- #38, on the front of Kirk
- Light at the visitors' center
- #37, the light in the Briar Lane Lot is attached to a telephone pole and is not light. This is a concern because from a distance it does not appear as a blue light. Fixing the light would solve this issue.
- #49 at Bressler
- Light outside of ZTA and Sigma Pi in Fraternity Circle is broken
- Light outside of Sigma Kappa in Fraternity Circle does not work
- Light outside of Aldrich Hall does not work
- Light on the elephant walk does not work
- Light by Butterfield Dining Hall does not work
- Light outside of the Multicultural Center and the Union does not flash when used

Visibility:

- #40, located in front of the library. From this light you cannot comfortably see another light
- #74, on Crawford Hall there is not another light in the area. This is the only light in a reasonable distance

Installment

- A blue light is needed in the area between Weldin Hall and Adams Hall behind these buildings (not along the road).
- The area surrounding both Wiley and Garrahy does not have a blue light. Another light is needed in this area.

Lighting and Safety Concerns

Residence Halls

- The lights located between Bressler and Hillside are set on a 7 pm timer. Due to the current season this area becomes dark before 7 pm so it is necessary to set the timer to an earlier time so this area can be lit when it becomes dark.
- The light in the parking lot next to Welding Hall is broken and needs repair.
- The area in the back of Fayweather Hall is dark and needs more lighting.
- The area surrounding Gorham Hall is dark and needs more lighting.
- Butterfield Road in front of Heathman is very dark and unsafe for students. Lighting is needed in this area. It is not safe for students to be walking in the dark, especially along a road where drivers may not be able to see them.
- The entrance to Hopkins is very dark and needs lighting.
- The path along side of Aldrich near the Fitness and Wellness center is in extremely poor condition. The asphalt is crumbling and the path is very uneven and unsafe to walk on. This sidewalk needs to be fixed.

Fraternity Circle

- The lights outside of Alpha Delta Pi are set on a 7 pm timer. Due to the current season, this area becomes dark before 7 pm so it is necessary so set the time to an earlier time so this area can be lit when it becomes dark.

Academic and Administrative Buildings

- A light is out near blue light #33 between the Union and Multicultural Center
- Blue light
- The light outside of Hutchinson -east does not work
- Building wallpacks Roosevelt –west 1 of 4 lit
- Lamp post by blue light #40 does not work/library (gooseneck)
- Pole lt. Tucker east
- Taft so.west next to blue light- pole lt. Not working
- Pole light on the (east) side of the library by Ballentine does not work
- The entire path of light posts in the back (north) of the library were not on (timer)
- The diagonal path to the bus stop from Chaffee (so.east) is not lit. The proposed solution was the installation of a lamp post or flood light from Chaffee.
- The light by Chaffee east (behind a large shrub) does not work and the cover has melted

- 3 lights are out on Woodward Hall east overhang /recessed fxtrs.
- 3 flood lights on the front of Chaffee so.east entry do not work. (to be replaced w. led's)
- There is a missing light fixture by the front stairs of Chaffee os.east entry (vandalism)
- Chaffee no.east entry- 4recessed fxtrs. Out
- Cbls so.east overhang- 1 lt.out
- Light @ bottom of the stairs by the CBLS so. does not work
- The Handicap ramp from Chaffee by the CBLS is unstable. It was installed as a temporary ramp, however it has never been removed.
- Several lights in the stairs of the Pharmacy building are broken. It is recommended that flood lights or lamps be installed rather than ground lights.
- The back (west) side of the Coastal Institute by the Pharmacy building is very dark and needs lighting. The trees in this area may need to be trimmed because they are very close to the building.
- 4 lights are out surrounding the Green Houses so.west area
- Greenhouses- all south- need led's installed at peaks to light walkway
- 1 light is out in the parking lot by the Coastal Institute
- 5 lights on the outside of the Coastal Institute do not work —so.east grnd. Lvl. wallpacks
- 2 lights on the back of Woodward east (wallpacks) do not work
- 2 lights on the south side of Tyler do not work (wallpacks)
- Woodward east 2 wallpacks out
- Crawford no.east crnr. replace 1 flood with 2 led floods
- The parking lot behind Kelley west is very uneven and could possibly be repaved
- The parking lot behind Kelley west is very dark and needs to be better lit. Installation of lights is required.(led's floods on west side required)
- A tree in the middle of the engineering quad is hollow and possess as a potential problem.
- The parking lot between Crawford/ Bliss is very dark and needs to be better lit. Installation of lights is required.
- A light attached to Bliss north needs a new bulb(replace 2 floods with led's)
- The parking lot by Bliss is very dark (needs investigation)
- Gilbreth/Kirk walkway- remove bollards and seal holes.Add 2 wallpacks.
- Gilbreth south/replace flood
- A light attached to Kirk west is hidden behind trees and does not work.
- A pole light by Kirk south does not work
- Blue light #38- no blue lt., no strobe
- A light along the street in front of Cherry Aud. does not work (middle "lollipop")
- Lights on the stairwell east into Cherry Aud. from the street do not work
- 2 lights on the west cntr. of the Fine Arts Center do not work (2 high floods and 1 wallpack- at exit from studio J)
- 2 lights on the lower level of the Fine Arts Center do not work-terrace east
- Lights on the corners of the Fine Arts Center in the front do not work (high wallpacks- replace 1 for 2 and seal remaining boxes)

- The path along the left (north) side of the Fine Arts Center leading to the parking lot is very dark
- 3 lights in the Fine Arts Center parking lot (west) near the building do not work (pole floods – replace all with led's)
- 2 poles in the Fine Arts Center are double lights and one light on each does not work and its on poles at south side of pkgng. lot.
- Blue light #3 –no blue lt.
- Lights on the road between the Fine Arts Center and University club does not work (Needs repairs and additional fxts.added) & pole #7
- Light attached to the tree in the University Club parking lot does not work. Installation of a pole light was discussed.
- Above blue light #65 the camera does not contain a camera
- The lights on the stairs by Bliss south entry do not work. A professor is working on a solar power installation project.
- Lights on the main entrances to East Hall and one on the side do not work (pendants above doors – east entrys)
- Besides East Hall there is a broken generator which no longer is being used and is falling apart. This generator needs to be removed.
- Flood light on the front of Adam's house does not work
- Blue light #36 - no blue lt.
- Light in the Visitor's Center small parking lot does not work (goose neck)
- IEP Parking lot lights do not work (timer)
- Several lights in the visitor parking lot do not work (to be replaced with led floods)
- 2 flood lights on the west side of Swan are no longer necessary and can be removed.
- A flood light on the back of Swan which is needed does not work.
- Light on the north side of Green Hall does not work
- Flood light on the south side of Ranger does not work
- Lights on the back doors(east) of Fogarty do not work(add 1 flood on so.east roof crnr.)
- Add gooseneck to pole on rd. at south side of Fogarty/ north side of International
- Pastore so.west high and west cntr.– (replace floods)
- Pastore Annex west at door - wallpack does not work
- Lights on the side of Quinn (south) by Pastore do not work (high floods-replace)
- Light on the side door of Quinn facing south does not work
- The road between the Presidents house and Fogarty is extremely dark. This area needs to be better lit. Installing flood lights to Fogarty to light this area were discussed.
- The bench by Fogarty along the road is in multiple pieces and needs to be repaired or removed.
- Light on the front of Pastore does not work
- 2 lights on the back of Quinn do not work
- Junction box behind Quinn needs to be screwed back on.

Athletic Complex

- Lights are out on both poles in the Mackle Keeney parking lot
- Recommended installation of a light in the corner of the Mackle Keeney parking lot coming from the front circle
- More light is needed in the far end of the Boss Arena parking lot
- By blue light #21, there is a light out at the bus stop
- Pole light out in the back of Mackle, in front of the soccer fields
- Multiple lights are out in the back of Tootel
- Multiple lights are out in the Ryan Center parking lot
-

Parking Lots

- The entrance to the Plainsfield and Flagg Road parking lots are very dark and need lighting.
- A street light is broken at the intersection of Flagg and Butterflied Road

Thank you for participation in the Fall 2013 Safety and Lighting Walk